

NOVARIS

Coaxial Surge Protectors

Installation Instructions



IMPORTANT: Please read these instructions carefully. Whilst straightforward, the installation of these devices is critical to their performance. Installation should only be carried out by a suitably qualified person in accordance with all relevant standards.

1. Introduction

1.1 These installation instructions apply to Novaris RF coaxial surge protectors with the following catalogue numbers:

Gas Tube Type
Cat No: **Cx-yy-zz-f-o**

- x Connection type.
- y Connector Gender, M=male, F=female.
- z Maximum continuous operating voltage.
- f Maximum frequency, fc (GHz).
- o Options.

- 1.2 Novaris Cx series gas discharge surge protectors are capable of passing RF signals to 3 GHz (limited by connector type).
- 1.3 Novaris CN 6G series gas discharge surge protectors are capable of passing RF signals to 6GHz. They come with CN type connectors only and have power ratings up to 150W maximum.



Figure 1: RF Coaxial Cable Protectors Range

2. Before Installation

2.1 For **Gas Tube Type**:
Ensure that the maximum continuous operating voltage of the Novaris RF coaxial protector is suitable for the RF power of the system:


Clamping voltage (V)	RF power (W)
90	15 - 25
230	100 - 150
350	350
600	1000
1000	2500

2.2 For **dimensions**, refer to the individual product data sheets

3. Installation

3.1 A Novaris RF coaxial surge protector should be installed at the termination points on *each end* of the cable run.

The ideal installation comprises a bulkhead protector (e.g. CN-FF-90-3) installed at the cable entry panel, figure 2a, if this is not possible, install a protector between the main feeder and flexible tail, alternatively at the equipment antenna receptacle, figure 2b.




*CN connector type shown for illustration purposes

Figure 2a: Connection of Novaris RF Coaxial Bulkhead Protectors

The outer conductor of the coaxial cable must be bonded to earth. This is best achieved by installing Novaris cable earth bonding kits. Recommended connection points for cable earth bonding kits are (Figure 6):

1. At the highest point of the vertical cable run to the tower
 2. At the lowest point of the vertical cable run to the tower
 3. At the entry point into the equipment hut to the cable entry panel or equipment earth bar
- 3.2 All outdoor installations should be made weatherproof using butyl rubber, cold shrink, vinyl mastic tape or suitable equivalent material over all connections and the protector itself.
- 3.3 Optional mounting kits in Table 1.



*CN connector type shown for illustration purposes

Figure 2b: Connection of Novaris RF Coaxial Inline Protectors


Optional Mounting Kits and Ordering Details		
Bracket (Cx-M)	Bracket with Sealing (Cx-M1)	DIN Rail Clip (Cx-D)
		

Table 1: Coaxial optional mounting kits

4. After Installation

- 4.1 The integrity of the installation should be verified by measuring the return loss and/or VSWR of the completed cable run.

Novaris RF coaxial surge protectors are extremely robust. Provided installation is performed correctly, Novaris coaxial cable protectors are virtually maintenance free. Periodic inspection of connections and weatherproofing is recommended.

A protector fault may be indicated by excessive VSWR / return loss, low resistance between the inner and outer conductors or intermittent degradation of system operation.




Figure 6: Typical Installation



72 Browns Road, Kingston, TAS. 7050
AUSTRALIA

Telephone: +61 3 6229 7233
E-mail: sales@novaris.com.au
Website: www.novaris.com.au

No.15, 2nd Floor Jalan Tembaga SD 5/2
Sri Damansara Industrial Park,
52200 Kuala Lumpur, Malaysia
Telephone: 603-6273 1599
E-mail: sales@novaris.com.my
Website: www.novaris.com.au